



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 416
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

www.lakegovernment.com

ADDENDUM NO. 2

Date: October 14, 2010

ITB 11-0202

Concrete Driveway and Flagpoles For Lake County Fire Station 109

This addendum is being issued to make the following clarifications to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. Respondents shall acknowledge receipt of this addendum by completing this form and returning it with the response. Failure to acknowledge this addendum may preclude consideration of the bid proposal award. **It is hereby confirmed that this addendum does not amend the current due date for bid responses.**

Change/add the following:

On page 4 of attachment 3 the "Typical Slab Joint Details" and "Typical Sections" call for "12 x 12 W5.4/5.4 WWM". As an alternative #4 rebar at 18" on center may be substituted.

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____

"Earning Community Confidence Through Excellence in Service"

DISTRICT ONE
JENNIFER HILL

DISTRICT TWO
ELAINE RENICK

DISTRICT THREE
JIMMY CONNER

DISTRICT FOUR
LINDA STEWART

DISTRICT FIVE
WELTON G. CADWELL